


DELHI JAL BOARD: GOVT. OF NCT OF DELHI
 OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
 ROOM NO. 208, VARUNALAYA PHASE-I
 KAROL BAGH, NEW DELHI 110005
 # 2355826*

No./DJB/EE (RWH/GWC)/2018/8259

DATED: 06/12/18

To,
 The Principal
 Lovely Sr. Sec. School
 New Loyalpur, Delhi-51



Sub:- Issue of design of rain water harvesting at Lovely Sr. Sec. School, New Loyalpur, Delhi-51.

.Sir,


Please refer to your application on the above subject. A drawing of rain water harvesting structure for the premises including conditions and layout drawing showing location of RWH structure are enclosed. It is to mention that design of rain water harvesting structure is based on the inputs provided by yourself/your representative.

The enclosed design is in form of technical assistance only. Proposed Three Nos. RWH structure **without bore well** of size 4.0 x 3.0 x 1.60 m, 4.0 x 3.0 x 1.50 m & 3.0 x 2.20 x 1.50 m and rain water conveyance system (storm water drain) should be provided and connected with RWH Structure in the above premises. The RWH structures be completed and intimate to this office

This is subject to the condition that in case of any restrictions on construction activities in the said premises by any other government authorities and court orders, then this design/approval deemed to stand cancelled. The storm water conveyance system shall be provided in place and made fully operational for efficiency of proposed RWH Structure.

PHOTOCOPY ATTESTED

BY NOTARY PUBLIC
 NEW DELHI (INDIA)


 EE (RWH/GWC)
 DELHI JAL BOARD
 VARUNALAYA PHASE-I,
 JHANDEWALLAN, N.D.-05

29 JAN 2019